

Analytical Report

Bill To: Pinchin West Ltd.	Project:	Lot ID: 1160803
Report To: Pinchin West Ltd.	ID: 13882U	Control Number:
200, 13775 Commerce Parkway	Name: SD#36 Water Sampling	Date Received: Sep 15, 2016
Richmond, BC, Canada	Location: Colebrook Elementary	Date Reported: Sep 15, 2016
V6V 2V4	LSD: 5404 125A Street,	Report Number: 2132396
Attn: Hussien Jaffer	Surrey	
Sampled By:	P.O.:	
Company: Pinchin West	Acct code:	

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
5508565	012-1A / Foun. - Corridor by Gym / Static / 22.8°C	0.0029	0.01	Below MAC
5508566	012-1B / Foun. - Corridor by Gym / Flushed / 22.8°C	0.0014	0.01	Below MAC
5508567	012-2A / Foun. - Near Rm 3 / Static / 22.8°C	0.0008	0.01	Below MAC
5508568	012-2B / Foun. - Near Rm 3 / Flushed / 22.8°C	0.0030	0.01	Below MAC

Approved by: 
Mathieu Simoneau
Operations Manager

Methodology and Notes

Bill To: Pinchin West Ltd.	Project:	Lot ID: 1160803
Report To: Pinchin West Ltd.	ID: 13882U	Control Number:
200, 13775 Commerce Parkway	Name: SD#36 Water Sampling	Date Received: Sep 15, 2016
Richmond, BC, Canada	Location: Colebrook Elementary	Date Reported: Sep 15, 2016
V6V 2V4	LSD: 5404 125A Street,	Report Number: 2132396
Attn: Hussien Jaffer	Surrey	
Sampled By:	P.O.:	
Company: Pinchin West	Acct code:	

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	15-Sep-16	Exova Surrey

References

US EPA US Environmental Protection Agency Test Methods

Guidelines

Guideline Description Health Canada GCDWQ
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014
Guideline Comments MAC = Maximum Acceptable Concentration
AO = Aesthetic Objective
OG = Operational Guideline for Water Treatment Plants
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at www.hc-sc.gc.ca

Comments:

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.