

**Analytical Report**

Bill To: Pinchin West Ltd.	Project:	Lot ID: <b>1159981</b>
Report To: Pinchin West Ltd.	ID: 13882U	Control Number:
200, 13775 Commerce Parkway	Name: SD#36 Water Sampling	Date Received: Sep 12, 2016
Richmond, BC, Canada	Location: Guildford Park	Date Reported: Sep 13, 2016
V6V 2V4	Secondary	Report Number: 2131346
Attn: Hussien Jaffer	LSD: 10707 146 Street, Surrey	
Sampled By: Bettsetseg Ulziikhuu	P.O.:	
Company: Pinchin West	Acct code:	

	Analyte Description	Lead Element		
	Unit of Measure	mg/L		
	Nominal Detection Limit	0.0001		
Sample Id	Description	Results	Guideline Limit	Guideline Comments
5504861	047-1A / North East Dish Sink in Hospitality / Static / 21.4 °C	0.0023	0.01	Below MAC
5504864	047-1B / North East Dish Sink in Hospitality / Flushed / 21.4 °C	0.0004	0.01	Below MAC
5504865	047-2A / North West Hand Sink in Hospitality / Static / 21.4 °C	0.0005	0.01	Below MAC
5504866	047-2B / North West Hand Sink in Hospitality / Flushed / 21.4 °C	0.0003	0.01	Below MAC
5504867	047-3A / Central Dish Sink Facing North in Hospitality / Static / 21.4 °C	0.0253	0.01	Above MAC
5504868	047-3B / Central Dish Sink Facing North in Hospitality / Flushed / 21.4 °C	0.0003	0.01	Below MAC
5504869	047-4A / Central East Dish Sink in Hospitality / Static / 21.4 °C	0.0050	0.01	Below MAC
5504870	047-4B / Central East Dish Sink in Hospitality / Flushed / 21.4 °C	0.0003	0.01	Below MAC
5504871	047-5A / Central West Dish Sink in Hospitality / Static / 21.4 °C	0.0564	0.01	Above MAC
5504872	047-5B / Central West Dish Sink in Hospitality / Flushed / 21.4 °C	0.0014	0.01	Below MAC
5504873	047-6A / South Dish Sink in Hospitality / Static / 21.4 °C	0.0011	0.01	Below MAC
5504874	047-6B / South Dish Sink in Hospitality / Flushed / 21.4 °C	<0.0001	0.01	Below MAC
5504875	047-7A / Sink in D100 Clothing and Textiles / Static / 21.4 °C	0.0058	0.01	Below MAC
5504876	047-7B / Sink in D100 Clothing and Textiles / Flushed / 21.4 °C	0.0012	0.01	Below MAC
5504877	047-8A / East Sink in D101 / Static / 21.4 °C	0.0097	0.01	Below MAC
5504878	047-8B / East Sink in D101 / Flushed / 21.4 °C	0.0006	0.01	Below MAC
5504879	047-9A / South East Sink in D101 / Static / 21.4 °C	0.0022	0.01	Below MAC
5504880	047-9B / South East Sink in D101 / Flushed / 21.4 °C	0.0002	0.01	Below MAC
5504881	047-10A / South West Sink in D101 / Static / 21.4 °C	0.0020	0.01	Below MAC
5504882	047-10B / South West Sink in D101 / Flushed / 21.4 °C	0.0004	0.01	Below MAC
5504883	047-11A / North West Sink in D101 / Static / 21.4 °C	0.0046	0.01	Below MAC
5504884	047-11B / North West Sink in D101 / Flushed / 21.4 °C	0.0002	0.01	Below MAC
5504885	047-12A / South West Sink in D101 / Static / 21.4 °C	0.0033	0.01	Below MAC
5504886	047-12B / South West Sink in D101 / Flushed / 21.4 °C	0.0003	0.01	Below MAC
5504887	047-13A / North West Sink in D101 / Static / 21.4 °C	0.0031	0.01	Below MAC
5504888	047-13B / North West Sink in D101 / Flushed / 21.4 °C	0.0002	0.01	Below MAC
5504889	047-14A / North East Sink in D101 / Static / 21.4 °C	0.0029	0.01	Below MAC
5504890	047-14B / North East Sink in D101 / Flushed / 21.4 °C	0.0003	0.01	Below MAC

Approved by:   
 Mathieu Simoneau  
 Operations Manager

## Methodology and Notes

Bill To: Pinchin West Ltd.	Project:	Lot ID: <b>1159981</b>
Report To: Pinchin West Ltd.	ID: 13882U	Control Number:
200, 13775 Commerce Parkway	Name: SD#36 Water Sampling	Date Received: Sep 12, 2016
Richmond, BC, Canada	Location: Guildford Park	Date Reported: Sep 13, 2016
V6V 2V4	LSD: 10707 146 Street, Surrey	Report Number: 2131346
Attn: Hussien Jaffer	P.O.:	
Sampled By: Bettsetseg Ulziikhuu	Acct code:	
Company: Pinchin West		

---

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	12-Sep-16	Exova Surrey

## References

US EPA US Environmental Protection Agency Test Methods

## Guidelines

Guideline Description Health Canada GCDWQ  
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014  
Guideline Comments MAC = Maximum Acceptable Concentration  
AO = Aesthetic Objective  
OG = Operational Guideline for Water Treatment Plants  
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at [www.hc-sc.gc.ca](http://www.hc-sc.gc.ca)

## Comments:

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.  
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.