



## Methodology and Notes

Bill To: School District #36	Project:	Lot ID: <b>1152514</b>
Report To: School District #36	ID: Hjorth Road Elementary	Control Number:
District Education Centre	Name: 001	Date Received: Jul 29, 2016
14033 92nd Avenue	Location:	Date Reported: Aug 5, 2016
Surrey, BC, Canada	LSD:	Report Number: 2122023
V3V 0B7	P.O.:	
Attn: Mary Campbell	Acct code:	
Sampled By:		
Company:		

---

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	03-Aug-16	Exova Surrey

## References

US EPA US Environmental Protection Agency Test Methods

## Guidelines

Guideline Description Health Canada GCDWQ  
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014  
Guideline Comments MAC = Maximum Acceptable Concentration  
AO = Aesthetic Objective  
OG = Operational Guideline for Water Treatment Plants  
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at [www.hc-sc.gc.ca](http://www.hc-sc.gc.ca)

## Comments:

- Lot created using the E-Coc import tool.

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.  
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.