

Analytical Report

Bill To: School District #36
 Report To: School District #36
 District Education Centre
 14033 92nd Avenue
 Surrey, BC, Canada
 V3V 0B7
 Attn: Mary Campbell
 Sampled By:
 Company:

Project:
 ID: Holly Elementary
 Name: 081
 Location:
 LSD:
 P.O.:
 Acct code:

Lot ID: **1152518**
 Control Number:
 Date Received: Jul 29, 2016
 Date Reported: Aug 5, 2016
 Report Number: 2122029

Analyte Description	Lead Element	Unit of Measure	Nominal Detection Limit
		mg/L	0.0001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
5471676	081 / Staff Room Sink / Static	0.0050	0.01	Below MAC
5471677	081 / Staff Room Sink / Flushed	0.0004	0.01	Below MAC
5471678	081 / W.F. by Book Room & Gym / Static	0.0393	0.01	Above MAC
5471679	081 / W.F. by Book Room & Gym / Flushed	0.0023	0.01	Below MAC
5471680	081 / Bubbler in Girls Changeroom / Static	0.105	0.01	Above MAC
5471681	081 / Bubbler in Girls Changeroom / Flushed	0.0038	0.01	Below MAC
5471682	081 / Bubbler in Boys Changeroom / Static	0.0142	0.01	Above MAC
5471683	081 / Bubbler in Boys Changeroom / Flushed	0.0014	0.01	Below MAC
5471684	081 / W.F. by Room 103 / Static	0.0086	0.01	Below MAC
5471685	081 / W.F. by Room 103 / Flushed	0.0007	0.01	Below MAC
5471686	081 / Bubbler in K. Room 106 / Static	0.0012	0.01	Below MAC
5471687	081 / Bubbler in K. Room 106 / Flushed	0.0025	0.01	Below MAC
5471688	081 / Multipurpose Room Sink / Static	0.0019	0.01	Below MAC
5471689	081 / Multipurpose Room Sink / Flushed	0.0007	0.01	Below MAC
5471690	081 / W.F. by Room 205 / Static	0.0032	0.01	Below MAC
5471691	081 / W.F. by Room 205 / Flushed	0.0008	0.01	Below MAC
5471692	081 / W.F. by Room 208 / Static	0.0092	0.01	Below MAC
5471693	081 / W.F. by Room 208 / Flushed	0.0009	0.01	Below MAC
5471694	081 / W.F. by Room 301 / Static	0.0011	0.01	Below MAC
5471695	081 / W.F. by Room 301 / Flushed	0.0002	0.01	Below MAC
5471696	081 / Bubbler in Room 404 / Static	0.0008	0.01	Below MAC
5471697	081 / Bubbler in Room 404 / Flushed	0.0002	0.01	Below MAC

Approved by: 
 Mathieu Simoneau
 Operations Manager

Methodology and Notes

Bill To: School District #36	Project:	Lot ID: 1152518
Report To: School District #36	ID: Holly Elementary	Control Number:
District Education Centre	Name: 081	Date Received: Jul 29, 2016
14033 92nd Avenue	Location:	Date Reported: Aug 5, 2016
Surrey, BC, Canada	LSD:	Report Number: 2122029
V3V 0B7	P.O.:	
Attn: Mary Campbell	Acct code:	
Sampled By:		
Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	03-Aug-16	Exova Surrey

References

US EPA US Environmental Protection Agency Test Methods

Guidelines

Guideline Description Health Canada GCDWQ
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014
Guideline Comments MAC = Maximum Acceptable Concentration
AO = Aesthetic Objective
OG = Operational Guideline for Water Treatment Plants
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at www.hc-sc.gc.ca

Comments:

- Lot created using the E-Coc import tool.

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.