


Analytical Report

Bill To: School District #36
 Report To: School District #36
 District Education Centre
 14033 92nd Avenue
 Surrey, BC, Canada
 V3V 0B7
 Attn: Mary Campbell
 Sampled By:
 Company:

Project:
 ID: Jessie Lee Elementary - July
 Name: 089
 Location:
 LSD:
 P.O.:
 Acct code:

Lot ID: **1151705**
 Control Number:
 Date Received: Jul 26, 2016
 Date Reported: Aug 4, 2016
 Report Number: 2121032

	Analyte Description Unit of Measure Nominal Detection Limit	Lead Element mg/L 0.0001		
Sample Id	Description	Results	Guideline Limit	Guideline Comments
5468412	089 / Staff Room Sink / Static / 22.0 °C	0.0448	0.01	Above MAC
5468413	089 / Staff Room Sink / Flushed / 22.0 °C	0.0012	0.01	Below MAC
5468414	089 / W.F. in Gym Storage/Entrance Room / Static / 22.0 °C	0.0311	0.01	Above MAC
5468415	089 / W.F. in Gym Storage/Entrance Room / Flushed / 22.0 °C	0.0051	0.01	Below MAC
5468416	089 / W.F. in Girls Changeroom / Static / 22.0 °C	0.0767	0.01	Above MAC
5468417	089 / W.F. in Girls Changeroom / Flushed / 22.0 °C	0.0051	0.01	Below MAC
5468418	089 / W.F. by Room 105B / Static / 22.0 °C	0.0351	0.01	Above MAC
5468419	089 / W.F. by Room 105B / Flushed / 22.0 °C	0.0033	0.01	Below MAC
5468420	089 / W.F. by Strongstart Washroom / Static / 22.0 °C	0.0346	0.01	Above MAC
5468421	089 / W.F. by Strongstart Washroom / Flushed / 22.0 °C	0.0024	0.01	Below MAC
5468422	089 / W.F. by Room 101 / Static / 22.0 °C	0.0029	0.01	Below MAC
5468423	089 / W.F. by Room 101 / Flushed / 22.0 °C	0.0007	0.01	Below MAC
5468424	089 / W.F. by Room 109 / Static / 22.0 °C	0.0087	0.01	Below MAC
5468425	089 / W.F. by Room 109 / Flushed / 22.0 °C	0.0012	0.01	Below MAC
5468426	089 / Multipurpose Room Sink / Static / 22.0 °C	0.0012	0.01	Below MAC
5468427	089 / Multipurpose Room Sink / Flushed / 22.0 °C	0.0002	0.01	Below MAC
5468428	089 / W.F. by Room 201 (Left) / Static / 22.0 °C	0.0166	0.01	Above MAC
5468429	089 / W.F. by Room 201 (Left) / Flushed / 22.0 °C	0.0014	0.01	Below MAC
5468430	089 / W.F. by Room 203 (Right) / Static / 22.0 °C	0.0119	0.01	Above MAC
5468431	089 / W.F. by Room 203 (Right) / Flushed / 22.0 °C	0.0011	0.01	Below MAC

Approved by: 
 Carol Nam, Dipl. T.
 Quality Officer

Methodology and Notes

Bill To: School District #36	Project:	Lot ID: 1151705
Report To: School District #36	ID: Jessie Lee Elementary - July	Control Number:
District Education Centre	Name: 089	Date Received: Jul 26, 2016
14033 92nd Avenue	Location:	Date Reported: Aug 4, 2016
Surrey, BC, Canada	LSD:	Report Number: 2121032
V3V 0B7	P.O.:	
Attn: Mary Campbell	Acct code:	
Sampled By:		
Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	28-Jul-16	Exova Surrey

References

US EPA US Environmental Protection Agency Test Methods

Guidelines

Guideline Description Health Canada GCDWQ
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014
Guideline Comments MAC = Maximum Acceptable Concentration
AO = Aesthetic Objective
OG = Operational Guideline for Water Treatment Plants
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at www.hc-sc.gc.ca

Comments:

- Lot created using the E-Coc import tool.

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.