

Analytical Report

Bill To: School District #36
 Report To: School District #36
 District Education Centre
 14033 92nd Avenue
 Surrey, BC, Canada
 V3V 0B7
 Attn: Mary Campbell
 Sampled By:
 Company:

Project:
 ID: Mary Jane Shannon
 Name: 054
 Location:
 LSD:
 P.O.:
 Acct code:

Lot ID: **1152522**
 Control Number:
 Date Received: Jul 29, 2016
 Date Reported: Aug 5, 2016
 Report Number: 2122033

Analyte Description	Lead Element	Unit of Measure	Nominal Detection Limit
		mg/L	0.0001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
5471715	054 / W.F. by Furnace Room / Static	0.0145	0.01	Above MAC
5471716	054 / W.F. by Furnace Room / Flushed	0.0011	0.01	Below MAC
5471717	054 / W.F. by Room 107 / Static	0.0056	0.01	Below MAC
5471718	054 / W.F. by Room 107 / Flushed	0.0008	0.01	Below MAC
5471719	054 / Staff Room / Kitchen Sink / Static	0.0018	0.01	Below MAC
5471720	054 / Staff Room/ Kitchen Sink / Flushed	0.0005	0.01	Below MAC
5471721	054 / Staff Room / Main Sink / Static	0.0068	0.01	Below MAC
5471722	054 / Staff Room / Main Sink / Flushed	0.0015	0.01	Below MAC
5471723	054 / Treehouse Room Kitchen Sink / Static	0.0010	0.01	Below MAC
5471724	054 / Treehouse Room Kitchen Sink / Flushed	0.0004	0.01	Below MAC
5471725	054 / W.F. by Room 103 / Static	0.0027	0.01	Below MAC
5471726	054 / W.F. by Room 103 / Flushed	0.0006	0.01	Below MAC
5471727	054 / W.F. by Room 101 / Static	0.0072	0.01	Below MAC
5471728	054 / W.F. by Room 101 / Flushed	0.0007	0.01	Below MAC
5471729	054 / Bubbler in Room 116 / Static	0.0030	0.01	Below MAC
5471730	054 / Bubbler in Room 116 / Flushed	0.0051	0.01	Below MAC
5471731	054 / W.F. by Room 200 / Static	0.0155	0.01	Above MAC
5471732	054 / W.F. by Room 200 / Flushed	0.0009	0.01	Below MAC
5471733	054 / W.F. by Room 204 / Stairwell / Static	0.0078	0.01	Below MAC
5471734	054 / W.F. by Room 204 / Stairwell / Flushed	0.0020	0.01	Below MAC
5471735	054 / W.F. by Room 112 / Stairwell / Static	0.0163	0.01	Above MAC
5471736	054 / W.F. by Room 112 / Stairwell / Flushed	0.0010	0.01	Below MAC
5471737	054 / Bubbler in K. Room 111 / Static	0.0108	0.01	Above MAC
5471738	054 / Bubbler in K. Room 111 / Flushed	0.0023	0.01	Below MAC

Approved by: 
 Mathieu Simoneau
 Operations Manager

Methodology and Notes

Bill To: School District #36	Project:	Lot ID: 1152522
Report To: School District #36	ID: Mary Jane Shannon	Control Number:
District Education Centre	Name: 054	Date Received: Jul 29, 2016
14033 92nd Avenue	Location:	Date Reported: Aug 5, 2016
Surrey, BC, Canada	LSD:	Report Number: 2122033
V3V 0B7	P.O.:	
Attn: Mary Campbell	Acct code:	
Sampled By:		
Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	03-Aug-16	Exova Surrey

References

US EPA US Environmental Protection Agency Test Methods

Guidelines

Guideline Description Health Canada GCDWQ
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014
Guideline Comments MAC = Maximum Acceptable Concentration
AO = Aesthetic Objective
OG = Operational Guideline for Water Treatment Plants
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at www.hc-sc.gc.ca

Comments:

- Lot created using the E-Coc import tool.

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.