

**Analytical Report**

<b>Bill To:</b> Pinchin West Ltd.	<b>Project:</b>	<b>Lot ID:</b> <b>1158889</b>
<b>Report To:</b> Pinchin West Ltd.	<b>ID:</b> 13882U	<b>Control Number:</b>
200, 13775 Commerce Parkway	<b>Name:</b> Pb Water Testing	<b>Date Received:</b> Sep 6, 2016
Richmond, BC, Canada	<b>Location:</b> SD36-Panorama Park Elementary	<b>Date Reported:</b> Sep 8, 2016
V6V 2V4	<b>LSD:</b> 12878 62 Avenue	<b>Report Number:</b> 2130484
<b>Attn:</b> Hussien Jaffer	<b>P.O.:</b> Surrey, BC	
<b>Sampled By:</b>	<b>Acct code:</b>	
<b>Company:</b>		

Analyte Description	Lead Element	Unit of Measure	Nominal Detection Limit
		mg/L	0.0001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
5500278	137-1A / Sink in Staff Room / Static / 20.9 °C	0.0051	0.01	Below MAC
5500279	137-1B / Sink in Staff Room / Flushed / 20.9 °C	0.0004	0.01	Below MAC

Approved by: Mathieu Simoneau  
 Operations Manager

Data have been validated by Analytical Quality Control and Exova's Integrated Data Validation System (IDVS). Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

## Methodology and Notes

Bill To: Pinchin West Ltd.	Project:	Lot ID: <b>1158889</b>
Report To: Pinchin West Ltd.	ID: 13882U	Control Number:
200, 13775 Commerce Parkway	Name: Pb Water Testing	Date Received: Sep 6, 2016
Richmond, BC, Canada	Location: SD36 -Panorama Park Elementary	Date Reported: Sep 8, 2016
V6V 2V4	LSD: 12878 62 Avenue	Report Number: 2130484
Attn: Hussien Jaffer	P.O.: Surrey, BC	
Sampled By:	Acct code:	
Company:		

---

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	06-Sep-16	Exova Surrey

## References

US EPA US Environmental Protection Agency Test Methods

## Guidelines

Guideline Description Health Canada GCDWQ  
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014  
Guideline Comments MAC = Maximum Acceptable Concentration  
AO = Aesthetic Objective  
OG = Operational Guideline for Water Treatment Plants  
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at [www.hc-sc.gc.ca](http://www.hc-sc.gc.ca)

## Comments:

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.  
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.