

**Analytical Report**

Bill To: Pinchin West Ltd.	Project:	Lot ID: <b>1160315</b>
Report To: Pinchin West Ltd.	ID: 13882U	Control Number:
200, 13775 Commerce Parkway	Name: SD#36 Water Sampling	Date Received: Sep 13, 2016
Richmond, BC, Canada	Location: Port Kells Elementary	Date Reported: Sep 14, 2016
V6V 2V4	LSD: 19076 88 Ave., Surrey	Report Number: 2131770
Attn: Hussien Jaffer	P.O.:	
Sampled By:	Acct code:	
Company: Pinchin West		

---

<b>Analyte</b>	Lead
<b>Description</b>	Element
<b>Unit of Measure</b>	mg/L
<b>Nominal Detection Limit</b>	0.0001

---

Sample Id	Description	Results	Guideline Limit	Guideline Comments
5506531	002-1A / Staff Room Annex Sink / Static / 21.6 °C	0.0047	0.01	Below MAC
5506532	002-1B / Staff Room Annex Sink / Flushed / 21.6 °C	0.0003	0.01	Below MAC

Approved by:   
Mathieu Simoneau  
Operations Manager

## Methodology and Notes

Bill To: Pinchin West Ltd.	Project:	Lot ID: <b>1160315</b>
Report To: Pinchin West Ltd.	ID: 13882U	Control Number:
200, 13775 Commerce Parkway	Name: SD#36 Water Sampling	Date Received: Sep 13, 2016
Richmond, BC, Canada	Location: Port Kells Elementary	Date Reported: Sep 14, 2016
V6V 2V4	LSD: 19076 88 Ave., Surrey	Report Number: 2131770
Attn: Hussien Jaffer	P.O.:	
Sampled By:	Acct code:	
Company: Pinchin West		

---

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	13-Sep-16	Exova Surrey

## References

US EPA US Environmental Protection Agency Test Methods

## Guidelines

Guideline Description Health Canada GCDWQ  
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014  
Guideline Comments MAC = Maximum Acceptable Concentration  
AO = Aesthetic Objective  
OG = Operational Guideline for Water Treatment Plants  
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at [www.hc-sc.gc.ca](http://www.hc-sc.gc.ca)

## Comments:

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.  
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.