

**Analytical Report**

Bill To: Pinchin West Ltd.	Project:	Lot ID: <b>1158857</b>
Report To: Pinchin West Ltd.	ID: 13882U	Control Number:
200, 13775 Commerce Parkway	Name: Pb Water Testing	Date Received: Sep 6, 2016
Richmond, BC, Canada	Location: SD 36	Date Reported: Sep 8, 2016
V6V 2V4	LSD: Semiahmoo Secondary	Report Number: 2130455
Attn: Hussien Jaffer	P.O.: 1785 148 Street	
Sampled By:	Acct code: Surrey, BC	
Company:		

---

<b>Analyte</b>	Lead
<b>Description</b>	Element
<b>Unit of Measure</b>	mg/L
<b>Nominal Detection Limit</b>	0.0001

---

Sample Id	Description	Results	Guideline Limit	Guideline Comments
5500121	049A / Main Flr Staff Room Sink / Static / 20.6 °C	0.0081	0.01	Below MAC
5500122	049B / Main Flr Staff Room Sink / Flushed / 20.6 °C	0.0002	0.01	Below MAC
5500123	049C / Main Flr Home Ec Sink South / Static / 20.6 °C	0.0049	0.01	Below MAC
5500124	049D / Main Flr Home Ec Sink South / Flushed / 20.6 °C	<0.0001	0.01	Below MAC
5500125	049E / Main Flr Class 108/103 Sink NW / Static / 20.6 °C	0.0438	0.01	Above MAC
5500126	049F / Main Flr Class 108/103 Sink NW / Flushed / 20.6 °C	0.0005	0.01	Below MAC

Approved by:   
Mathieu Simoneau  
Operations Manager

## Methodology and Notes

Bill To: Pinchin West Ltd.	Project:	Lot ID: <b>1158857</b>
Report To: Pinchin West Ltd.	ID: 13882U	Control Number:
200, 13775 Commerce Parkway	Name: Pb Water Testing	Date Received: Sep 6, 2016
Richmond, BC, Canada	Location: SD 36 Semiahmoo Secondary	Date Reported: Sep 8, 2016
V6V 2V4	LSD: 1785 148 Street	Report Number: 2130455
Attn: Hussien Jaffer	P.O.: Surrey, BC	
Sampled By:	Acct code:	
Company:		

---

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	06-Sep-16	Exova Surrey

## References

US EPA US Environmental Protection Agency Test Methods

## Guidelines

Guideline Description Health Canada GCDWQ  
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014  
Guideline Comments MAC = Maximum Acceptable Concentration  
AO = Aesthetic Objective  
OG = Operational Guideline for Water Treatment Plants  
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at [www.hc-sc.gc.ca](http://www.hc-sc.gc.ca)

## Comments:

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.  
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.