


Analytical Report

Bill To: School District #36	Project:	Lot ID: 1153370
Report To: School District #36	ID: South Meridian Elementary	Control Number:
District Education Centre	Name: 118	Date Received: Aug 5, 2016
14033 92nd Avenue	Location:	Date Reported: Aug 9, 2016
Surrey, BC, Canada	LSD:	Report Number: 2123069
V3V 0B7	P.O.: 2121917	
Attn: Mary Campbell	Acct code:	
Sampled By:		
Company:		

Sample Id	Description	Analyte Description Unit of Measure Nominal Detection Limit	Lead Element mg/L 0.0001	Results	Guideline Limit	Guideline Comments
5474945	118 / W.F. by Gym & BW / Flushed	0.0023	0.01	Below MAC		
5474946	118 / Staff Room Sink / Static	0.0035	0.01	Below MAC		
5474947	118 / Staff Room Sink / Flushed	0.0004	0.01	Below MAC		
5474948	118 / Multipurpose Room Sink / Static	0.0204	0.01	Above MAC		
5474949	118 / Multipurpose Room Sink / Flushed	0.0008	0.01	Below MAC		
5474950	118 / W.F. by Library / Static	0.0119	0.01	Above MAC		
5474951	118 / W.F. by Library / Flushed	0.0026	0.01	Below MAC		
5474952	118 / W.F. by Room 404 / Static	0.0068	0.01	Below MAC		
5474953	118 / W.F. by Room 404 / Flushed	0.0024	0.01	Below MAC		
5474954	118 / K. Room 307/308 Kitchen Sink / Static	0.0101	0.01	Above MAC		
5474955	118 / K. Room 307/308 Kitchen Sink / Flushed	0.0007	0.01	Below MAC		
5474956	118 / Bubbler in K. Room 307 / Static	0.0029	0.01	Below MAC		
5474957	118 / Bubbler in K. Room 307 / Flushed	0.0005	0.01	Below MAC		

Approved by: 
 Matthew Norman, BSc, PChem
 Operations Chemist

Methodology and Notes

Bill To: School District #36	Project:	Lot ID: 1153370
Report To: School District #36	ID: South Meridian Elementary	Control Number:
District Education Centre	Name: 118	Date Received: Aug 5, 2016
14033 92nd Avenue	Location:	Date Reported: Aug 9, 2016
Surrey, BC, Canada	LSD:	Report Number: 2123069
V3V 0B7	P.O.: 2121917	
Attn: Mary Campbell	Acct code:	
Sampled By:		
Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	05-Aug-16	Exova Surrey

References

US EPA US Environmental Protection Agency Test Methods

Guidelines

Guideline Description Health Canada GCDWQ
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014
Guideline Comments MAC = Maximum Acceptable Concentration
AO = Aesthetic Objective
OG = Operational Guideline for Water Treatment Plants
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at www.hc-sc.gc.ca

Comments:

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.