

Analytical Report

Bill To: School District #36
Report To: School District #36
District Education Centre
14033 92nd Avenue
Surrey, BC, Canada
V3V 0B7
Attn: Mary Campbell
Sampled By:
Company:

Project:
ID: Various Schools (1)
Name: A
Location: Surrey Traditional
LSD:
P.O.:
Acct code:

Lot ID: **1158115**
Control Number:
Date Received: Aug 31, 2016
Date Reported: Aug 31, 2016
Report Number: 2128975

	Analyte Description Unit of Measure Nominal Detection Limit	Lead Element mg/L 0.0001		
Sample Id	Description	Results	Guideline Limit	Guideline Comments
5496613	080 / W.F. by Room 222 / Static / 21.8 °C	0.0375	0.01	Above MAC
5496614	080 / W.F. by Room 222 / Flushed / 21.8 °C	0.0128	0.01	Above MAC

Approved by: 
Mathieu Simoneau
Operations Manager

Methodology and Notes

Bill To: School District #36	Project:	Lot ID: 1158115
Report To: School District #36	ID: Various Schools (1)	Control Number:
District Education Centre	Name: A	Date Received: Aug 31, 2016
14033 92nd Avenue	Location: Surrey Traditional	Date Reported: Aug 31, 2016
Surrey, BC, Canada	LSD:	Report Number: 2128975
V3V 0B7	P.O.:	
Attn: Mary Campbell	Acct code:	
Sampled By:		
Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	31-Aug-16	Exova Surrey

References

US EPA US Environmental Protection Agency Test Methods

Guidelines

Guideline Description Health Canada GCDWQ
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014
Guideline Comments MAC = Maximum Acceptable Concentration
AO = Aesthetic Objective
OG = Operational Guideline for Water Treatment Plants
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at www.hc-sc.gc.ca

Comments:

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group.
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.